

ZESTAWIENIE WYNIKÓW BADAŃ LABORATORYJNYCH

Warstwa	Próba	Rodzaj gruntu		Barwa	Waleczki	CaCO ₃	W _n	W _p	W _L	I _p	I _L	I _C	τ	ρ	k _{USBSC}	k _{Hazen}	k _{zm.grad.}	k _{st.grad.}	U	M ₀	M
		PN-86/B02480	PN-EN ISO 14688 1				[%]	[%]	[%]	[%]	[-]	[-]	[kPa]	[g/cm ³]	[m/s]	[m/s]	[m/s]	[m/s]	[-]	[kPa]	[kPa]
II	o3_2,0	Gπ	siCl	c.brązowy	3/2,	I kl.	31,7%	28,6%	59,4%	30,8%	0,10	0,90	65,0								
	o4_1,8	Gπ	siCl	c.brązowy	3/3,	I kl.	34,0%	30,3%		30,0%	0,13	0,87	70,0								
III	o2_1,0	Ps	MSa	beżowy			5,0%								0,00007	0,0002			2,08		
IV	o1_2,0	Pd	MSa	beżowy			6,7%								0,00005	0,0002			1,89		
	o3_4,0	Pd	MSa	beżowy			18,6%								0,00004	0,0001			2,38		
	o5_2,5	Pd	MSa	beżowy			8,4%								0,00004	0,0001			2,19		